CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #:PRSUBD20192722Address:392 NW CHIPMAN RD, Unit:ES, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
DE - Miscellaneous PWORKS Inspection		Joe Starlin	Partial	Monday, March 02, 2020
Informational:				
1	Misc	2-7-20 9:40am I spoke with Mike Confer about the pole location. I informed him that we were waiting on awsers from Evergy. 1:18pm Mike with capital is needing to move a pedistol pole due to AT&T line being in the way. I told him we would check on it and let him know. After speaking with Erin Capital is allowed to move the pedistol pole to the south side of the sidewalk.		
Informational:				
2	Misc	on site and have placed a board out holes for signal for No. 8 after lunch. 1:30	o work taking place at this t new power pole at the south pole's No. 2 and 10 at this ti pm They have the hole boar de. Capital has the transforr	n west corner. They have me. They will be boaring d out for number 8 and
Corrective Action Required:				
3	Misc	-	on site setting the steel and ing on pouring Monday 2-17	
Informational:				
4	Misc	and will be pouring at 2pm installed. 2:02pm Terracor corner first. Terracon ran and they can pour. 2:55pn	s on site cleaning out the ho n. All holes are at correct dep n is on site for testing. They a test on the first truck. He wa n They have poured the nort . 3:10pm The are pouring th	oth and have steel are pouring at the NW as good with the tests th side and are pouring in

		Island. 3:25pm They are pouring the last pole base on the SE corner. 3:34pm 10,8,9, and 2 pole bases are poured.
		2-18-20 10:22am Fordyce Concrete was on site at 10am and I have collected the concrete ticket.They are pouring out the rest of the bases with 4K mix. They have been told to cover everything poured with blankets due to temps. 2:55pm They have everything covered with blankets.
Informati	ional:	
5	Misc	Joe Starlin 03/02/2020 7:29 AM On Friday 2-28-20 Capital met there breaks for strength on the concrete and removed all blankets. Monday 3-2-20 They are planning on wrecking all forms.

Comments: