

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192895
Address: 120 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|------------------------|
| Gas Service Inspection - Residential | Patrick Schonfeldt | Failed | Monday, March 02, 2020 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Provide bond on gas line - Secure gas line at fireplaces - Pressure steady at 24 psi |
|---|------|--|

Comments: