



1100 W Cambridge Circle Drive
Suite 700
Kansas City, Kansas 66103
913.627.9040

2121 Moodie Road
Lawrence, Kansas 66046
785.856.9600

2011 NW Topeka Blvd
Topeka, Kansas 66608
785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 1/31/20

WEATHER: Partly Sunny

CFS
PERSONNEL: A. Goodhope, P.E.

TEMPERATURE: 33-39

REPORT #: 19-1125-dr- 62

TYPE OF SERVICE BEING PERFORMED

OTHER STRUCTURAL STEEL

DEVIATION FOUND: YES

DEVIATION CORRECTED:

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- **DEVIATION:**

DEVIATION LOCATION: Skidmore Load Test on TC Bolts

DEVIATION DESCRIPTION: Most of the A490 1" diameter bolts failed to meet the minimum design strength of 67.2k.

- Observed a Skidmore pre-qualification load test on 18 lots of A325 and A490 TC bolts. See attachments for test results.