



1100 W Cambridge Circle Drive
Suite 700
Kansas City, Kansas 66103
913.627.9040

2121 Moodie Road
Lawrence, Kansas 66046
785.856.9600

2011 NW Topeka Blvd
Topeka, Kansas 66608
785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 1/21/20

WEATHER: Overcast

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 18-35

REPORT #: 19-1125-dr- 52

TYPE OF SERVICE BEING PERFORMED

SOILS FOUNDATIONS

DEVIATION FOUND: NO

CONCRETE REINFORCING STEEL

DEVIATION CORRECTED:

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Inspected footings for From B.2-1 to 1.4-A continuous
- All footings met required bearing capacity and size. Reinforcing steel found to be in compliance with plans and specifications.
- Inspected reinforcing steel placement for Wall from E to G on 4.1 line & col. @ E-5.2 (final inspection)
- Reinforcing steel verified to be in compliance with plans and specifications.