



1100 W Cambridge Circle Drive
Suite 700
Kansas City, Kansas 66103
913.627.9040

2121 Moodie Road
Lawrence, Kansas 66046
785.856.9600

2011 NW Topeka Blvd
Topeka, Kansas 66608
785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 1/14/20

WEATHER: Overcast

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 35-45

REPORT #: 19-1125-dr- 48

TYPE OF SERVICE BEING PERFORMED

CONCRETE PLACEMENT

DEVIATION FOUND: NO

CONCRETE REINFORCING STEEL

DEVIATION CORRECTED:

OTHER WATER BARRIER SYSTEM

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of concrete for Wall- E-8 to 21' east, columns 8'2" east of B-2 & column F-12 interior.
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.
- Observation of water barrier system placed from 12 - A to B.5 - 12 on exterior walls as per job site specifications.