



1100 W Cambridge Circle Drive  
 Suite 700  
 Kansas City, Kansas 66103  
 913.627.9040

2121 Moodie Road  
 Lawrence, Kansas 66046  
 785.856.9600

2011 NW Topeka Blvd  
 Topeka, Kansas 66608  
 785.270.6447

**DAILY FIELD REPORT**

CLIENT: Pearl Real Estate Company  
 919 N East Street  
 Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor  
 Apartments  
 Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 1/31/20

WEATHER: Overcast

CFS  
 PERSONNEL: M. Simpson

TEMPERATURE: 30-40

REPORT #: 19-1125-dr- 59

**TYPE OF SERVICE BEING PERFORMED**

**CONCRETE** PLACEMENT

**DEVIATION FOUND: NO**

**CONCRETE** REINFORCING STEEL

**DEVIATION CORRECTED:**

**OTHER** EPOXY INSTALLATION

**ORIGINAL DEVIATION DATE:**

**WORK ACCOMPLISHED THIS DATE:**

- Monitored placement of concrete for Wall - from A-1 to E-1
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.
- Observed drill & epoxy of # 4 bars at 19 locations from A- 1 to B- 1 per RFI #65 .