



1100 W Cambridge Circle Drive
Suite 700
Kansas City, Kansas 66103
913.627.9040

2121 Moodie Road
Lawrence, Kansas 66046
785.856.9600

2011 NW Topeka Blvd
Topeka, Kansas 66608
785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 2/17/20

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 40-55

REPORT #: 19-1125-dr- 74

TYPE OF SERVICE BEING PERFORMED

CONCRETE PLACEMENT

DEVIATION FOUND: NO

CONCRETE REINFORCING STEEL

DEVIATION CORRECTED:

OTHER WATER STOP

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of concrete for Wall- from 3-J to 5-J.
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
Reinforcing steel verified to be in compliance with plans and specifications.
- Observation of installation of water stop system to exterior walls from A-1 to J-1 & backfill w/ clean rock. As per specifications.