



1100 W Cambridge Circle Drive
Suite 700
Kansas City, Kansas 66103
913.627.9040

2121 Moodie Road
Lawrence, Kansas 66046
785.856.9600

2011 NW Topeka Blvd
Topeka, Kansas 66608
785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 2/10/20

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 25-35

REPORT #: 19-1125-dr- 69

TYPE OF SERVICE BEING PERFORMED

SOILS FOUNDATIONS

DEVIATION FOUND: NO

SOILS COMPACTION MONITORING

DEVIATION CORRECTED:

MASONRY GROUT / REINFORCING STEEL

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Observation of footing compaction & bearing for wall "N" and bedding placement from station 0 + 00 to station 7 + 20.
- All footings met required bearing capacity and size.
- Monitored placement of grout and inspected reinforcing steel at CMU wall bond beam above garage entrance from J/9.1 to 10.0 elevation 98.0 to 100.4
- Reinforcing steel verified to be in compliance with plans and specifications.