



1100 W Cambridge Circle Drive
 Suite 700
 Kansas City, Kansas 66103
 913.627.9040

2121 Moodie Road
 Lawrence, Kansas 66046
 785.856.9600

2011 NW Topeka Blvd
 Topeka, Kansas 66608
 785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
 919 N East Street
 Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
 Apartments
 Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 2/21/20

WEATHER: Sunny

CFS
 PERSONNEL: M. Simpson

TEMPERATURE: 20-45

REPORT #: 19-1125-dr- 78

TYPE OF SERVICE BEING PERFORMED

CONCRETE PLACEMENT

DEVIATION FOUND: NO

CONCRETE REINFORCING STEEL

DEVIATION CORRECTED:

CONCRETE CYLINDER PICK UP

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of concrete for Walls- E.2 to F.2 on 5 line & F.2 to F.9 on 8 line.Elevator pit stem walls @ G-5 . Columns @ 2.1,2.4,3.2,3.8,4.2,4.4,8.5 & 8.7 on J line.
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.
- Cylinder pick up of set 207.