



1100 W Cambridge Circle Drive
Suite 700
Kansas City, Kansas 66103
913.627.9040

2121 Moodie Road
Lawrence, Kansas 66046
785.856.9600

2011 NW Topeka Blvd
Topeka, Kansas 66608
785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 2/19/20

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 20-45

REPORT #: 19-1125-dr- 76

TYPE OF SERVICE BEING PERFORMED

MASONRY GROUT / REINFORCING STEEL

DEVIATION FOUND: NO

CONCRETE PLACEMENT

DEVIATION CORRECTED:

CONCRETE REINFORCING STEEL

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of grout and inspected reinforcing steel at CMU south stairwell walls @ C.5 -1, elevation from 96.0 to 100.0
- Reinforcing steel verified to be in compliance with plans and specifications.
- Monitored placement of concrete for The interior wall column at F-1
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.