

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192672
Address: 1534 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Curb - Proof Roll	Marquelle Williams	Passed	Tuesday, March 03, 2020

Informational:
1 Misc

JANUARY 6, 2019

Vogler Trucking was onsite doing a proof roll on the curbs. All curbs passed.

Informational:
2 Misc

The site sat with no activity all winter so another proof roll was required.

I observed the proof roll for both the curbs and the parking lot.

The proof roll passed with little to no deflection for both curb and parking lot.

I verified the correct load weight. A photo of the load ticket has been uploaded to the system.

Comments: