

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192860
Address: 1901 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, March 03, 2020

Corrective Action Required:

1 Misc

FRAMING:

- Windows (>9 sq ft and <18" above floor) at NE bedroom must be tempered glass windows
- Install lvl beams below kitchen island per plan

ELECTRICAL:

- Protect wiring below service panel

Comments: