

ANALYTICAL REPORT

February 15, 2020

Work Order: 1B00887

Page 1 of 3

Report To
John Dimauro City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 02/14/2020 10:30AM Collector: Client Phone: (816) 969-1200 PO Number: Routine Analysis

Project : Redford Construction

Project Number: Eagle Creek 16th Plat

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1B00887-01 Water Line 1				Matrix:Drink Wtr		Collected: 02/14/20 09:30	
Total Coliforms	<1.0 MPN/100ml	1.0	1DB0510	9223B-QT	CLJ	02/14/20 15:30	
E. Coli	<1.0 MPN/100ml	1.0	1DB0510	9223B-QT	CLJ	02/14/20 15:30	
1B00887-02 Water Line 2				Matrix:Drink Wtr		Collected: 02/14/20 09:30	
Total Coliforms	<1.0 MPN/100ml	1.0	1DB0510	9223B-QT	CLJ	02/14/20 15:30	
E. Coli	<1.0 MPN/100ml	1.0	1DB0510	9223B-QT	CLJ	02/14/20 15:30	
1B00887-03 Water Line 3				Matrix:Drink Wtr		Collected: 02/14/20 09:40	
Total Coliforms	<1.0 MPN/100ml	1.0	1DB0510	9223B-QT	CLJ	02/14/20 15:30	
E. Coli	<1.0 MPN/100ml	1.0	1DB0510	9223B-QT	CLJ	02/14/20 15:30	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

February 15, 2020

Page 2 of 3

Work Order: 1B00887

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2020
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2020
MO-KC	Missouri Department of Natural Resources	140	04/30/2020
SIA1X	Iowa Department of Natural Resources	95	02/01/2021

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

Keystone

PAGE _____ OF _____

(If Applicable)

FORM: CCR 7-97