

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193144
Address: 1229 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, March 04, 2020

Corrective Action Required:

1 Misc

****THIS IS A 3RD INSPECTION SCHEDULED WITH NO PLAN ON SITE. THE LIST BELOW IS NOT A COMPLETED LIST OF DEFICIENCIES DUE TO NO PLAN ON SITE
2ND RE-INSPECTION FEE ASSESSED 3/4/20

FRAMING:

-Anchor sill plates within 12" of breaks; some anchor missing washer&nut

-Install collar ties per code

****Code requires collar ties along lvl ridge, located in the upper 1/3 of roof height, be installed at no more than 4 ft interval.**

Comments: