

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193057
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	John Jackson	Partial	Tuesday, December 24, 2019

Informational:
1 Misc Contractor installed approximately 120' of 24" HPDE storm pipe on Line A . Sta 4+00 to Sta 5+20 12/20/19 Friday. Contractor will work on Monday 12/23/19 and continue to install pipe on Line A.

Informational:
2 Contractor installed approximately 120' of 24" HDPE pipe up to Storm inlet A1.

Comments: