

Lee's Summit, MO 64063

**CITY OF LEE'S SUMMIT**  
**DEVELOPMENT SERVICES**

**FAX: 816-969-1201**

## Emergency Call-Out Inspection Report

ADDRESS: 611 SW 3 <sup>rd</sup> Street	I.C.: Assistant Chief McCaw
PROPERTY OWNER: LANGSFORD DEVELOPMENT INC	
OCCUPANT: Shining Light Music	
PHONE#: 816.347.0099	

Time of Call to respond: 04:58	
Time of Arrival on scene: 05:40	
Description: Building fire	
Location of Damages: Entire roof structure and interior	
Entire interior of building was consumed by flames and the roof was completely destroyed. Electrical power to the multiple meters at the west exterior wall was disconnected at the service pole by Everyg. Spire shut off the main gas supply valve and removed the meters. Fire department shut off water service at the meter. As "hot spots" continued to appear FD continued to apply extinguishing water. Situation stable.	
JB returned later the same day to check status and found a contractor preparing to erect perimeter safety fence.	
Gas Service: Shut off; meters removed	
Electrical Service: Disconnected at service pole	
Water Service: Shut off by FD	
List of placards posted: JB placed "UNSAFE" placards at four locations around the building perimeter	
Permits required: Will be required for demolition or restoration	
Time Departed: 06:50	
INSPECTOR: John Borns	DATE: 2/9/2020