

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191770  
Address: 2861 NE INDEPENDENCE AVE, Unit:101, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Thursday, March 05, 2020

Corrective Action Required:

1	Misc	-FIRE DEPT. APPROVAL REQUIRED -ALL ABOVE-CEILING CIRCUITS SERVING OPERATION ROOMS SHALL MEET REQUIREMENT OF 517.13(A) -SCREW AND SEAL PATCHES FOR ABOVE-CEILING OPENING IN 1-HR WALL IN STERILIZER RM -INSTALL RESTROOM SIGNAGES -INSTALL KNEE PROTECTIONS UNDER SINKS IN RESTROOMS AND CORRIDORS -INSTALL HOSPITAL-GRADE RECEPTACLE NEAR SINK IN POST-OP RM
---	------	---

**\*\*OK TO STOCK. DO NOT OCCUPY AT THIS POINT**

**Comments:**