

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191496
Address: 1800 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, March 06, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Submit as graded plot plan for review- Seal around all exterior light fixtures- Seal all exterior penetrations- Sump pump discharge minimum 36" distance to foundation
---	------	---

Comments: