

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200117
Address: 1816 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Friday, March 06, 2020

Corrective Action Required:

1	Misc	- No address posted - - Erosion control required at back of lot to protect creek. Front of lot erosion control OK.- - Dead ends not allowed on DWN north side basement. -
---	------	---

Comments: