

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182387
Address: 2023 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Partial	Friday, March 06, 2020

Corrective Action Required:

1	Misc	west of garage partial to top of wall on CMU block living quarters : exterior walls ok to insulate
---	------	--

Corrective Action Required:

2	FIRST FLOOR	BUNK KITCHEN AREA- TOP OF 1HR FIRE WALL PARTIAL INSPECTION FOR ROCK ONLY, NO LOWER WALLS INSPECTED TO THIS POINT
---	-------------	--

Comments: