

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20200044
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	Joe Starlin	Partial	Friday, March 06, 2020

Informational:	
1 Misc	2-21-20 10:45am All erosion controls on this site are in place with a few areas needing clean up. The superintendent said he would address the issues.
Informational:	
2 Misc	3-6-20 They have spoils close to the curb on both the North South and East West roads. I told the crew on site that they need erosion controls in place. 1:23PM They are installing silt fence on the north side and should be done with all erosion controls at the end of the day.

Comments: