

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500  
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Sanitary Sewer - Vacuum</b>	Ronald Paynter	Partial	Friday, March 06, 2020

Informational:

1	Misc	Manhole 2-2 held 10 PSI for over 3 minutes. RP 12-4-19
---	------	--

Informational:

2	Misc	Manholes 1-1, 1-2, 1-3, 1-4 and 1-5 all passed vacuum testing. RP 1-7-2020
---	------	--

Informational:

3	Misc	The following manholes held for 2 1/2 minutes. 1-6, 1-7, 3-2. Manhole 3-1 FAILED the test and will need to be retested once it's been repaired. RP 2-7-20
---	------	---

Informational:

4	Misc	The following manholes passed their vacuum test: 1-8, 1-9, 1-10, 1-11, 1-12, 1-13, 3-1 and 4-1. RP 3-5-20
---	------	---

Informational:

5	Misc	The following manholes passed their vacuum test: 1-8, 1-9, 1-10, 1-11, 1-12, 1-13, 3-1 and 4-1. RP 3-5-20
---	------	---

Informational:

6	Misc	The following manholes passed their vacuum test: 8-0, 8-1, 8-2, 8-3, 8-4, 8-5, 8-6 and 8-7. RP 3-6-20
---	------	---

**Comments:**