

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193144  
Address: 1229 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, March 06, 2020

Corrective Action Required:

1	Misc	-Ground electrical service to ufer nad copper water service line
---	------	--

**\*\*Service grounding connection to water has not been done. The grounding connection to ufer rebar is not proper in compliance with listing of product.**

**Comments:**