

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 64081  
2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:   | Inspector:     | Outcome: | Date:                    |
|---|----------------|----------|--------------------------|
| <b>DE - Erosion Sediment Control (ESC) Inspection</b> | Ronald Paynter | Partial  | Saturday, March 07, 2020 |

### Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | Went to meet Norm from Axiom to discuss the temporary silt trap for the detention basin. When I arrived on site, I saw that Bair Excavating worked over the weekend and they stripped the entire site of vegetation along with not installing the silt trap. Will meet again on site tomorrow to go over these problems with the contractors. RP 2-24-20 |
|---|------|--|

### Informational:

|   |      |  |
|---|------|--|
| 2 | Misc | Erosion controls are in place along with silt trap. Gutter buddy's are placed along Pryor protecting the storm system. RP 3-7-20 |
|---|------|--|

### Comments: