

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182652  
Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	John DiMauro	Failed	Monday, March 09, 2020

Corrective Action Required:  
6 Misc EROSION CONTROL INSPECTION FAILED

There are areas on site along SW LADDERBACK DR where the silt fence has failed and is allowing silt and mud to run into the storm water collection system. Please make corrections to the silt fence asap to contain the silt and mud on the site.

**Comments:**