

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20171604

Address: 3510 SW HOLLYWOOD DR, Unit:G1, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Failed	Monday, March 09, 2020

Corrective Action Required:

1	Misc	Provide missing nails STHD14 hold downs - Provide missing screws to studs HDU2 hold downs - Provide anchor bolts within 12" of plate breaks - Provide flashing at wood window sills -
---	------	--

**Comments:**