

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20171605

Address: 3510 SW HOLLYWOOD DR, Unit:G2, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, March 09, 2020

Corrective Action Required:

1	Misc	Provide missing nails STHD14 hold downs - Provide screws to studs HDU2 hold downs - Provide anchor bolts within 12" of plate breaks - Provide flashing at wood window sills -
---	------	--

Comments: