

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192296
Address: 1901 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, March 10, 2020

Corrective Action Required:

1	Misc	Seal exterior light fixtures - Provide guardrail or raise grade to 30" front stoop - Install dishwasher discharge hose above sink bowl - Install stove with anti tip device - Provide deck pier inspection - Sidewalk still partial pass - Tighten self closing hinges garage door - Install shower enclosures check temp glass - Tighten anti siphon device at water main - Provide receptacle cover behind wet bar - Provide final grade & sod - Provide (2) 3" screws each exterior hinge & strike plate deck door - Provide 36" splash blocks - Maintain erosion control - Provide fixture or cover plate outside single car garage door -
---	------	--

Comments: