

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192857
Address: 4512 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, March 10, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Provide joist hanger above bottom step basement- provide solid blocking between joist under island- provide Simpson STHD14RJ per plan corner near front stoop- provide boca plate mud room at floor- seal upward penetration- provide solid security blocking patio door- provide PFH portal frame garage per plan detail 12 S2.0- nail double truss together master- fasten exhaust fans with metallic tape- provide TJC57 master bath / closet per truss layout- provide HUS26 master bedroom per truss layout |
|---|------|--|

Comments: