CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193198

Address: 204 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Michael Harkins Failed Tuesday, March 10,

Residential 2020

Corrective Action Required:

1 Misc - Provide solid security blocking exterior doors

- provide anchor bolts steel columns suspended garage

- provide anchor bolt within 12" of plate break storage behind stairs
- address double 14" LVL kitchen/ dinette clipped to 6" bearing
- -address double 14" LVL kitchen/ family room

Plan shows concealed girder truss

- address I beam garage plan shows SCH 40 column not stud pack
- seal exterior penetration basement bath light fixture

Comments: