



March 4, 2020

Summit Homes

Re: 4413 SW Nautilus Pl
Lot 21 Creekside at Raintree

Apex Engineers, Inc. observed the preparation for the suspended garage slab at the above referenced address.

The garage slab will be suspended. The forms and reinforcing steel were found to be clean, well aligned, and properly supported.

Discrepancy:

- Steel deck is not attached to steel beam. Engineer of Record to address. Pour at own risk.

Contingent upon EOR approval of discrepancy noted above, the suspended slab forms and reinforcing steel appear to be in general compliance with the city approved plans. This report does not constitute approval by the enforcing jurisdiction.

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel. If changes in the condition of the site occur and Apex Engineers, Inc. is not allowed the opportunity to re-evaluate the site to respond to any of these changes, our firm cannot be responsible for the effect of any of the conditions that differed from those reported herein.

Please call if Apex Engineers, Inc. can be of further assistance.

