

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182652
Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Wednesday, March 11, 2020

Corrective Action Required:

1	Misc	EROSION CONTROL INSPECTION FAILED
---	------	-----------------------------------

There are areas on site along SW LADDERBACK DR where the silt fence has failed and is allowing silt and mud to run into the storm water collection system. Please make corrections to the silt fence asap to contain the silt and mud on the site.

Corrective Action Required:

2	Misc	EROSION CONTROL INSPECTION FAILED
---	------	-----------------------------------

There are areas on site where the silt fence is down and needs corrected.

At the intersection of LADDERBACK & RIVER TRAIL there is mud and silt washing from the site and collecting on the street and in the storm system. Please clean the street and correct the ESC devices asap.

Comments: