

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190138
Address: 2240 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Wednesday, March 11, 2020

Corrective Action Required:

1	Misc	Provide wrap for exposed plumbing in men's & women's restroom & break room sink - Check grounding clamp light pole bases parking lot. -
---	------	--

Corrective Action Required:

2	Misc	OK TO STOCK EQUIPMENT AND MOVE BOOKS FROM OTHER LOCAITON. NOT TO BE OPEN TO THE PUBLIC.
---	------	--

Comments: