

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192072
Address: 1537 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sidewalk Inspection	John DiMauro	Failed	Wednesday, March 11, 2020

Informational:

1	Misc	They didn't have time to set up the sidewalk. They will call in another inspection tomorrow. RP 3-4-20
---	------	--

Corrective Action Required:

2	Misc	No expansion material between the ramp and the new sidewalk. The first four sidewalk panels from the ADA ramp are uneven and have low spots along the edges. Make corrections to the sidewalk panels.
---	------	---

Comments: