

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193404
Address: 855 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Wednesday, March 11, 2020

Corrective Action Required:

1	Misc	-Remove all insulation paper facing or cover up with membrane meeting fire and smoke develop index -Secure all Mc within 12" of boxes and enclosures -Missing supply air above middle of building
---	------	---

Comments: