

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191603
Address: 2421 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Wednesday, March 11, 2020

Corrective Action Required:

1	Misc	-Provide permanent address - provide final grade , sod, splash blocks - provide (2) 3" screws each exterior hinge & strike plates - provide hardware garage door - provide anti siphon device at water shutoff
---	------	--

Corrective Action Required:

2	Misc	-Provide permanent address - provide final grade , sod, splash blocks - provide (2) 3" screws each exterior hinge & strike plates - provide hardware garage door - provide anti siphon device at water shutoff
---	------	--

Comments: