



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20193506	Date:	March 11, 2020
Project Title:	SIMPLY THREADS	Applicant:	
Location:	893 SW LEMANS LN, LEES SUMMIT, MO 64082		
Type of Work:			ADVANTAGE FIRE PROTECTION SYSTEMS INC
Occupancy Group:	M		404 B NW 11TH ST
Description:	TENANT FINISH FOR CLOTHING		BLUE SPRINGS, MO 64015
STORE		Primary:	(816) 224-3400
Construction Type:	Type VB (Unprotected)		
Map Page:	215A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. (Informational Purposes)
1. Current annual inspection tag on riser
2. Update records showing NFPA 2016

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.