

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193198
Address: 204 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, March 12, 2020

Corrective Action Required:

1	Misc	- Provide letter from engineer of record for below - Address double 14" LVL kitchen/dinette clipped to 6" bearing - address double LVL kitchen / family room Plan shows concealed girder truss - address I beam garage plan shows SCH 40 columns not stud pack
---	------	--

Comments: