

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20192650

Address: 855 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064855 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064851 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Storm - Pipe</b>	John Jackson	Partial	Thursday, November 14, 2019

Informational:

1 Misc

Contractor ( Bair Excavation) installed approximately 70' of 18" HDPE storm pipe. 0+00 to 70+00. Gravel was layed to ensure storm pipe meets grade with a 0.75% slope.

Informational:

2

Flowable fill was poured across all storm pipe layed in Parking Lot area as per plan. Contractor proposed plan to mix black color to concrete mix 8" concrete and match parking lot grade (this option was approved). At this time it appears that contractor will not use this option but stay with the orginal plan of finishing with a 2" asphalt cap as-per plans. See Asphalt Concrete Street Repair C 11.0

**Comments:**