

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192650

Address: 855 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064855 NE WOODS CHAPEL RD, LEES
SUMMIT, MO 64064851 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064851
NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|--------------|----------|--------------------------------|
| DE - Roof Drain | John Jackson | Partial | Thursday, November 14, 2019 |

Informational:

1 Misc

Contractor installed the roof drain system as per plan see C 5.0 ST/03, 04, 05, 06, & 07. Contractor installation stopped at the stub coming out of the drain that will connect to 4" drains running from the roof.

Comments: