PLANS REVIEW CONDITIONS

Permit No: PRCOM20192156 Date: March 13, 2020

Project Title: MCKEEVER'S MARKET Applicant:

Location:

ALL SAFE FIRE PROTECTION LLC 840 NW PRYOR RD, LEES SUMMIT, MO 64081 8113 N OAK TRFWY STE D

Type of Work: KANSAS CITY, MO 64118 Occupancy Group: M

NEW GROCERY STORE Description:

FOUNDATION PERMIT - PRCOM20192982

Construction Type: Type IIB (Unprotected)

Map Page: 194D Primary: (816) 492-7202

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Michael Weissenbach **Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. (Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test and a flow test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City **Codes and Ordinances.**