

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192857
Address: 4512 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, March 13, 2020

Corrective Action Required:

1	Misc	- Provide joist hanger above bottom step basement - provide Simpson STHD14RJ per plan corner near front stoop - seal upward penetration top plate dining room / breakfast nook
---	------	--

Comments: