CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20182736

Address: 2505 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

Inspected On: Friday, March 13, 2020

Inspected By: Michael Harkins

Expiration Date: 4/17/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Michael Harkins Temporary C of O Friday, March 13,

Codes Residential 2020

Corrective Action Required:

Misc - Provide final grade, sod, splash blocks

- seal exterior penetrations gas meter, meter can, AC disconnect