

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193404  
Address: 855 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Friday, March 13, 2020

Corrective Action Required:

1	Misc	-Approval required from: Water, Planning, Field Service -Complete roof flashing and downspout -Paint exterior gas piping for protection against corrosion -Install max 30 amp breaker for RTU -Install backflow preventors for ice machine (RPZ) and other machines (BFP) per plan
---	------	--

**Comments:**