

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Mark Harding	Not Ready	Monday, March 16, 2020

Partial Correction:

1 Misc

GAS PIPING PRESSURE TEST & VISUAL INSPECTION ON:
PIPING FROM COLUMN WRAP OUTSIDE FRONT ENTRANCE TO FIREPLACE ENCLOSURE; GAS PIPING FRMO EXTERIOR TO INSIDE POOL PUMP ROOM HOLDING 15 PSI;
2ND FAILED INSPECTION ON GAS LINE TO FIREPLACE EXTERIOR, NEEDS TO BE 12" UNDER GRADE

Comments: