

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182607
Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Monday, March 16, 2020

Partial Correction:

1	THE FOLLOWING AREAS ARE APPROVED	OK TO COVER 5/8" MOLD-RESISTENT TYPE "X" GWB AT TUB/SHOWER WALLS: ONE LAYER AT 4TH FLOOR, 3RD FLR, 2ND FLR, 1ST FLR; TWO LAYERS WHERE REQUIRED AT SHEAR WALLS, TUBS/SHOWERS ADJACENT TO STAIRWELLS, ELEVATOR, CORRIDORS - ALL FLOORS JOIST CAVITIES: BASEMENT UTILITY ROOMS: DATA/ELECT RM: WALLS 1 LAYER; 2ND LAYER; ELEVATOR EQUIP RM: WALLS 1 LAYER; 2ND LAYER; WALLS: WALLS 1 LAYER; 2ND LAYER; OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE: BASEMENT LEVEL: 1ST FLOOR: 1ST LAYER; 2ND LAYER; 2ND FLOOR: 1ST LAYER; 2ND LAYER; 3RD FLOOR: 1ST LAYER; 2ND LAYER; 4TH FLOOR:
---	----------------------------------	--

Corrective Action Required: 2 STAIR TOWER 1	3rd floor RC channel all units ceiling, corridor walls & ceiling SOUTH; 4TH FLOOR CEILING- WALLS STAIR WELL- 4TH FLOOR 1ST,2ND LAYER UNIT SIDES 3RD FL 1ST LAYER OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE: SOUTH STAIRWELL #1: BASEMENT: N&E WALLS WELL FACE 1ST & 2ND LAYERS 1ST FLOOR: WELL FACE 1ST LAYER; 2ND LAYER; 2ND FLOOR: WELL FACE 1ST LAYER; 2ND LAYER; 3RD FLOOR: WELL FACE 1ST LAYER; 2ND LAYER; 4TH FLOOR: WELL FACE 1ST LAYER; 2ND LAYER TOWER: WALLS 1ST LAYER; HIGH & LOW CEILINGS 1ST LAYER + 2ND LAYER; 1st layer outside
Corrective Action Required: 3 STAIR TOWER 2	NORTH: 4TH FL- 4TH FLOOR 1ST,2ND LAYER UNIT SIDES STAIRWELL : 3RD FL 1ST LAYER; OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE: NORTH STAIRWELL #2: BASEMENT LEVEL: WELL FACE 1ST LAYER; 2ND LAYER; 1ST FLOOR: WELL FACE 1ST LAYER; 2ND LAYER 2ND FLOOR: WELL FACE 1ST LAYER; 2ND LAYER 3RD FLOOR: WELL FACE 1ST LAYER; 2ND LAYER 4TH FLOOR: WELL FACE 1ST LAYER; 2ND LAYER TOWER: WALLS 1ST LAYER; HIGH & LOW CEILINGS 1ST LAYER + 2ND LAYER; 1st layer outside
Corrective Action Required: 4 ELEVATOR 1	1ST,2ND LAYER ELEVATOR SHAFT INSIDE 1st layer outside CEILING 1,2,3,HAT CHANNEL.

Comments: