

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191681
Address: 560 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Mark Harding	Failed	Monday, March 16, 2020

Corrective Action Required:

1	Misc	PARTIAL-INCOMPLETE GAS LINE AT WEST END, 2 LOCATIONS NOT EXTENDED THROUGH ROOF HOLD 15 PSI. RETEST WHEN GAS IS COMPLETE WITHIN 6FT OF UNIT.
---	------	--

Comments: