

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172511
Address: 221 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Michael Harkins	Failed	Monday, March 16, 2020

Corrective Action Required:

1	Misc	- provide tamper proof caps A/C condensers, provide fire extinguishers per plan, 301 provide self closing door, fire caulk penetrations at water heater, 302 anti tip device stove, self closing door, fire caulk penetrations at water heater, 303 fire caulk penetrations at water heater, anti tip device stove, self closing door 304 fire caulk penetrations water heater, self closing door, 305 fire caulk penetrations at water heater, self closing door 306 self closing door, fire caulk penetrations at water heater 307 self closing door, fire caulk water heater penetrations 308 GFCI bathroom open neutral, self closing door, fire caulk penetrations at water heater 207 self closing door, fire caulk penetrations at water heater, 208 self closing door, fire caulk water heater penetrations, 206 anti tip device stove, self closing door, fire caulk. penetrations at water heater, 205 self closing door, fire caulk penetrations at water heater, anti tip device stove, 204 self closing door, seal, Fire caulk penetrations at water heater, 203 self closing door, fire caulk penetrations at water heater,
---	------	---

202 self closing door, fire caulk penetrations at water heater,
201 fire caulk penetrations at water heater

Comments: