## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRSITE20192218Address:1901 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
DE - Sidewalk Inspection		Joe Starlin	Partial	Friday, February 14, 2020	
Informational:					
1	Misc	11-5-19 They are setting up sidewalk forms around the pond. They have been told to stay ADA compliant and use white cure. They are planning to pour tomorrow. The temp is going to drop below freezing so they have been told to cover all concrete with blankets.			
Informational:					
2	Misc	They need to adjust there	waiting on concrete, to pore forms for six inch concrete to the header and are now s crete tickets.	e for around the pond per	
Informat	tional:				
3	Misc	11-7-19 8:22am They are s goes around the pond.	setting forms at this time fo	r the walking path that	
Informational:					
4	Misc	-	es out. The first concrete a 50ft. Cook Flatt & Strobel is	-	
Informational:					
5	Misc	and are working there wa have been informed to st	9 They started there pour c ay up hill to the east. They a cay ADA compliant and to us on site and they are finishir	re using the 4K mix. They se white cure evenly.	
Informational:					

6	Misc	11-14-19 They have started to pour the walk going around the west side of the pond. 2:42pm They have pulled off the header and will be curing and covering with blankets.			
Informational:					
7	Misc	11-15-19 9:11am They are setting up for sidewalk on the east side of the site. They will be pouring at 9:30am. 11:18am They are pouring the path along Pryor. They started at the north end and are working there way to the south.1:50pm They have poured everything running north and south and are pouring from the east to the west at the north end of the pond. They will be covering with blankets due to overnight temperature.			
Informational:					
8	Misc	11-18-19 9:01am They are pulling blankets and forms on the walk. They need to replace two panels.			
Informational:					
9	Misc	11-18-19 2:38pm They have replaced the panels that were out of compliance on the walking path.			
Informational:					
10	Misc	11-19-19 All sidewalk poured was checked with a smart level and is ADA compliant.			
Informa					
11	Misc	12-11-19 2:52pm They are pouring the sidewalk at the north end of the park. They were told to have 5ft joints with a center cut. the sidewalk in front of the bathrooms has 10ft joints and either needs to have joints sawed in or be replaced.			
Informa	tional:				
12	Misc	12-12-19 10:45am They have formed up the sidewalk at the corner of Pryor and Chipman and it is compliant at this time. The sidewalk on Chipman is formed up and compliant at this time as well. Freeman is setting up sidewalk at the park.			
Informational:					
13	Misc	1-6-2020 Freeman is pouring sidewalk south of the restrooms next to the porta potty. CFS is on site for testing.			
Informational:					
14	Misc	1-30-20 3:18pm They have poured sidewalk all the way around the restroom building at the park. They did not call for a pre-inspection or notify myself or the third party inspector about the pour. There is no cure on it at this time. I am not sure what time they finished the pour.			
Informational:					
15	Misc	2-3-20 SAPP are digging out and preparing the forms for the sidewalk in front of the restrooms. 12:00 noon. They have installed new aggregate and will be compacting it later today. I checked the walking path north and south of the restrooms with my level and it all is ADA compliant.			
Informa	tional:				
16	Misc	2-4-20 9:19am The forms are set and new aggregate in place. Due to weather there is no activity today.			
Informational:					
17	Misc	2-11-20 8:59am They are preparing to pour the walking path in front of the restrooms. 11:23am Penny's Concrete is on site and ESS are pouring the walking path. The third party inspector was on site for testing.			

**Comments:**