

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20193404
Address: 855 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064
Inspected On: Tuesday, March 17, 2020
Inspected By: Khanh Nguyen
Expiration Date: 4/17/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Tuesday, March 17, 2020

Corrective Action Required:

1	Misc	-Approval required from: Water, Planning, Field Service -Complete roof flashing and downspout -Paint exterior gas piping for protection against corrosion -The gas meter encroaches into the accessible pathway. Move the meter as close to the wall as possible
---	------	---